



CITY OF PARK RIDGE

505 BUTLER PLACE
PARK RIDGE, IL 60068
TEL: 847/ 318-5291
FAX: 847/ 318-6411
TDD:847/ 318-5252
URL:<http://www.parkridge.us>

DEPARTMENT OF COMMUNITY PRESERVATION AND DEVELOPMENT
BUILDING SAFETY DIVISION

Gas Lines Guidelines

All gas lines shall meet:
2015 International Residential Code
2015 International Fuel Gas Code
2015 International Mechanical Code
NICOR regulations

General

- GAS LINES shall be in rigid metallic metal piping when above grade. (Municipal Code 15-4-4)
- Gas meters must be installed in a location approved by the gas utility company.
- Gas lines must be properly supported and secured in place. Vibration isolation and structural safety must be adhered to.
- All manufactured products must be installed as per manufacture's installation instructions.
- Ignition sources must be a minimum of 18" above hazardous location such as garages.
- Gas piping other than CSST must be bonded (G2411/310)
- All exterior underground piping must be buried a minimum of 12 inches. (G2415.10/404.10)
- All exterior above ground piping must be elevated a minimum of 3.5 inches. (G2415.7/404.7)
- Non metallic pipes require a tracer yellow wire
- Shut off valves are required for each appliance and must be accessible.
- Contact us for a pre-back-fill and a final inspection.

Contact the City of Park Ridge upon completion for all rough and final inspections at 847-318-5291.

Review the City Ordinances at www.parkridge.us

To purchase code books, contact ICC at:800-214-4321 / www.intlcode.org

Construction Documents (approved SITE copies) shall be available at all times at the job site. Any alterations to the approved SITE copies must be submitted to the City of Park Ridge in triplicate for review and approval.

CALL JULIE BEFORE YOU DIG....It's FREE - nationwide number 8 - 1 - 1