



CITY OF PARK RIDGE

505 BUTLER PLACE
PARK RIDGE, IL 60068
TEL: 847/ 318-5291
FAX: 847/ 318-6411
TDD:847/ 318-5252
URL:<http://www.parkridge.us>

DEPARTMENT OF COMMUNITY
PRESERVATION AND DEVELOPMENT
BUILDING SAFETY DIVISION

Temporary Heating Equipment Guidelines

Shall meet:
2015 International Fire Code

- Temporary tanks shall not be placed within 5' of the property lines.
- There shall be no open burning of materials in an unapproved container. No smoke causing a nuisance is not allowed.
- Temporary Heating Equipment shall be used as per manufactures' instructions.
- Equipment shall be a minimum of ten (10) feet away from all combustibles, i.e. plastic tarps.
- Equipment shall be fixed in place.
- Equipment requires a fire estingusher to be present on the site.
- Smoking or open flames are prohibited where flammable or combustibles are stored.
- An approved cabinet shall be required for all flammable or combustible liquids in excess of 10 gallons are stored.
- When in use, someone must be present.

FOR INSPECTIONS CALL: 847-318-5291

**CONSTRUCTION DOCUMENT (S) SHALL BE AVAILABLE AT
ALL TIMES AT THE SITE.**

**ANY ALTERATIONS TO THE APPROVED PLANS MUST BE SUBMITTED IN
TRIPLICATE FOR REVIEW AND APPROVAL**